


Pt-100 RTD Temperature Transmitters

Precision, Isolated, Universal

Model 20/1



The model 20/1 is a precision, loop powered 2-wire transmitter with galvanic isolation between its input and the current-loop output signal. It provides the necessary circuitry for amplification and linearization of signals from RTD sensors. The input circuit can accept 2 or 3 wire RTD's for either a direct or a differential temperature measurement. An optional LCD indicator is available to indicate actual temperature in °C or °F.

The 20/1 can be easily ranged without requiring special tools or board modifications. The transmitter is a member of Mescon's family of advanced Universal Input transmitters, which may be readily reconfigured to accept other popular inputs such as Thermocouples, DC mV/mA/Volt and Potentiometers.

A TEST terminal provides a 40-200 mV signal which is proportional to the 4-20mA output. Applying a DVM to the TEST terminals allows monitoring and verification of the output without interrupting or disconnecting the current loop.

FEATURES:

- 2-wire transmitter system
- User selectable input types, 2 or 3 wire RTD's
- Eliminates ground loop errors
- Over 1000 Volts Isolation
- Differential measurement mode
- Wide ranging ZERO and SPAN
- Output TEST terminals
- DIN rail mounting

AVAILABLE OPTIONS:

- 3-1/2 digit backlit LCD indicator
- 4-wire Pt-100 sensors
- Other Pt, Ni, NiFe, Cu RTD sensors
- NEMA 4X or NEMA 7 enclosure



MESCON
Technologies, Inc.

9318 Gulfstream Road, Suite A, Frankfort, IL 60423
Phone: 815-464-5004
Fax: 815-464-5003
E-Mail: mescon@mescontec.com
Web: www.mescontec.com

Pt-100 RTD Temperature Transmitters

Precision, Isolated, Universal


Model 20/1

SPECIFICATIONS:


Input.....	Pt-100, 2-wire, 3-wire, differential
Output	4-20mA, 2-wire, limiting @ <28 mA
Input Span	10°C (18°F) min. to 800°C (1440°F) max.
Calibration accuracy	±0.1% of span, BSLF, referred to sensor's actual temperature
Lead wire compensation	Automatic, for 3-wire sensors
Burnout detection	Upscale, Standard
Temperature stability	Better than ±0.02% of span/°F
Isolation	>1000 VDC or peak AC
Maximum Load	$R_{max} = (V_{supply} - 10V) \div 20mA$
C.M.R.R.....	>120 db, DC to 60 Hz
Output ripple	<0.01% of span (to 5KHz)
Adjustments	> ±25% for both ZERO and SPAN
Power supply range	10 - 50 VDC, polarity protected
Operating Temp.....	-20°C to 70°C, (0°F to 160°F)
Mounting	DIN rail (35mm) or panel with adapter
Humidity	0 to 95% RH, non-condensing

All specifications are subject to change without notice.

ORDERING INFORMATION



Please request our ordering and calibration diskette describing the rest of Mescon's products.



Wiring Instructions:

1. Connect the RTD sensor leads to input terminals 1, 3, and 4 according to the wiring diagram.
2. Connect the positive supply lead to terminal 10 (+V).
3. Connect the negative supply lead to terminal 11 (-V).
4. Connect the system ground to terminal 9.
5. Turn the power on and observe input/output parameters

Note: To monitor the output without breaking the current loop, connect a digital voltmeter between terminal 12 (Test) and terminal 11 (-V). An internal 10.0 ohm resistor in series with the current loop provides a 40-200mV signal for the 4-20mA current output.

Calibration and Adjustments:

It is assumed that the unit undergoing calibration has been properly ranged at the factory or workshop.

1. Connect an RTD simulator to the 20/1 input terminals according to the wiring diagram.
2. Complete the output loop using a power supply and a precision digital current indicator. Turn the power on.
3. Set the input to the desired minimum signal and adjust the ZERO pot until the current indicator reads 4.00mA.
4. Set the input to the desired maximum signal and adjust the SPAN pot until the current indicator reads 20.00mA.
5. Repeat steps 3 & 4 until no further adjustment is needed.

Note: If the unit can not be calibrated to the desired range, it should be returned to the workshop for proper ranging.



MESCON
Technologies, Inc.

9318 Gulfstream Road, Suite A, Frankfort, IL 60423

Phone: 815-464-5004

Fax: 815-464-5003

E-Mail: mescon@mescontec.com

Web: www.mescontec.com

Distributed By: